

District Name: Samastipur

Government of Bihar
Public Health Engineering Department

Sl. No.	Block	Panchyat	Village	Location of Source	Parameters													Remarks
					pH	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F		
1	Khanpur	Rebra	Rebra	A Y International School	7.2	128	85	56	12	6	16	60	0.2	BDL	5	0.4	safe	
Desirable Limit*					6.5-8.5		500	300	75		250	200	1.0	45	200	1.0		
Permissible Limit* in absence of alternate source					NR		2000	600	200		1000	600	NR	NR	400	1.5		

Permit Number 103/18/20
Lab Assistant

3.2.2020
Chemist

12/03/2020
Executive Engineer

[Signature]
Principal
A.Y. International School
Rebra, Samastipur

[Signature]
Chairman
A.Y. International School
Rebra, Samastipur